



INDIVIDUAL TEST
CERTIFICATE

Filter Data :

Filter Type	HC-H13-A-7-406-406-150-FB-P	Order No	4513.1621.4040
Dimensions (mm)	406x406x150	Serial Number	A 202306294
Filter Class According to EN 1822	H13	Nominal Flow Rate (m ³ /h)	270 m ³ /h
Δp Initial (Pa)	55	Min.Efficiency at MPPS %	99,95

Test Data :

Aerosol Type	DEHS	Passed (Yes / No)	YES
Date	2.06.2023	Signature	

We hereby certify that the product described above complies with the terms of the order.

We certify that the filter with the serial number above has passed the leak-test according to EN 1822:2019 & ISO 29463.